

Pittsburg County, Oklahoma
COUNTY PURCHASING OFFICE
 Pittsburg County Court House
 McAlester, Oklahoma
 Phone: (918) 423-4934

INVITATION TO BID

PLEASE REVIEW TERMS AND CONDITIONS ON REVERSE SIDE RELATING TO SUBMISSION OF THIS BID.

Notarized Affidavit completions and signature required on reverse side.

DATE ISSUED	2-Nov-20
PAGE 1 OF _____	

BID NUMBER BID # 3	BID CLOSING DATE AND HOUR November 13, 2020 @ 5:00PM	REQUIRED DELIVERY DATE <small>Days after award of Purchase Order</small>
TERMS:		DATE OF DELIVERY:

Item	Quantity	Unit of issue	DESCRIPTION	Unit Price	Total
			<p>Board of County Commissioners wish to advertise for the following for the Blue Volunteer Fire Department:</p> <p>One (1) Used, Pumper-Apparatus</p> <p>See Specifications Attached</p> <p><u>PLEASE MARK CLEARLY ON FRONT OF SHIPPING ENVELOPE BID & BID NUMBER</u></p>		

TERMS AND CONDITIONS

1. Sealed bids will be opened in the Commissioner's Conference Room, Pittsburg County Courthouse, McAlester, Oklahoma, at the time and date shown on the invitation to bid form.
2. Late bids will not be considered. Bids must be received in sealed envelopes (one to an envelope) with bid number and closing date written on the outside of the envelope.
3. Unit prices will be guaranteed correct by the bidder.
4. Firm prices will be F.O.B. destination.
5. Purchases by Pittsburg County, Oklahoma, are not subject to state or federal taxes.
6. This bid is submitted as a legal offer and any bid when accepted by the County constitutes a firm contract.
7. Oklahoma laws require each bidder submitting a bid to a county for goods or services to furnish a notarized sworn statement of non-collusion. A form is supplied below.
8. Bids will be firm until delivered.

(DATE)

6.1201E+19

AFFIDAVIT: I, the undersigned, of lawful age, being first duly sworn on oath say that he (she) is the agent authorized by the bidder to submit the above bid. Affiant further states that the bidder has not been a party to any collusion among bidders in restraint of freedom of competition by agreement to bid at a fixed price or to refrain from bidding; or with any state official or employee as to quantity; quality or price in the prospective contract or any other terms of said prospective contract; or in any discussions between bidders and any state official concerning exchange of money or other thing of value for special consideration in the letting of a contract; that the bidder/contractor has not paid, given or donated or agreed to pay, give or donate to any officer or employee of the State of Oklahoma (or other entity) any money or other thing of value, either directly or indirectly in the procuring of the award of a contract pursuant to this bid.

Subscribed and sworn before this _____ day
of _____ 20_____ (seal)

Firm: _____

My commission expires _____ Signed by: _____ Title: _____
(MANUAL SIGNATURE OF UNDERSIGNED)

NOTARY PUBLIC (CLERK OR JUDGE) Address: _____ Phone: _____
City: _____ State _____
Zip _____

NOTE: Other terms and conditions can be added at the discretion of the county officers.

RESOLUTION

21-129

To

Advertise

The Board of County Commissioners, Pittsburg County, met in regular session on Monday, November 2, 2020.

WHEREAS, the Board of County Commissioners wish to advertise for the following for Blue Volunteer Fire Department:

One (1) Used, Pumper-Apparatus

A bid package containing complete specifications and an "Invitation to Bid" are available at the Pittsburg County Clerk's Office, 115 E. Carl Albert Pkwy, Room 103, McAlester, Oklahoma, 74501 or online at pittsburg.okcounties.org.

THEREFORE, each competitive bid submitted to the County must be accompanied with an affidavit for filing with the competitive bid form, as required by 19 O.S. § 421.1(C).

Sealed bids will be received and filed with the Pittsburg County Clerk until Friday, November 13, 2020 at 5:00 p.m. All bids received after 5:00 p.m. on Friday, November 13, 2020 WILL NOT BE OPENED. Bids will be opened on Monday, November 16, 2020 at 10:00 a.m. in the Board of County Commissioners Conference Room, 115 E. Carl Albert Pkwy, McAlester, Oklahoma. Bid(s) will be awarded to the lowest and/or best bidder. The Board of County Commissioners, Pittsburg County, reserves the right to reject any and all bids and re-advertise.

BOARD OF COUNTY COMMISSIONERS
PITTSBURG COUNTY, OKLAHOMA

ATTEST:

CHAIRMAN



VICE-CHAIRMAN



MEMBER

COUNTY CLERK





Bid Specifications for Used Pumper-Apparatus

Pumper-Apparatus Cab/Chassis:

Pumper-Apparatus will be a **2001** or newer

Pumper-Apparatus will be **Red** in color and **4-Door Cab**

Pumper-Apparatus will have a **Cummins ISC 330 Engine** or equivalent and **Allison MD3060P Transmission** or equivalent

Approximate mileage of Pumper-Apparatus **not to exceed 35,000 miles**

Approximate hour-use of Pumper-Apparatus **not to exceed 4,200 hours**

Pumper-Apparatus will have **Transmission Cooler; Air Conditioning; Heavy Duty Alternator; Manual Windows; AM/FM Radio**

Pumper-Apparatus Body:

The body of Pumper-Apparatus will have a Maximum Length that will not exceed 29'4"

The body of Pumper-Apparatus will have a Maximum Height that will not exceed 9'10"

Pumper-Apparatus Supplementary Equipment and Storage Compartments:

The Pumper-Apparatus will be equipped with the minimum following fire-response equipment: one [1] TFT Deck Gun with/ground stand or equivalent; two [2] 1.75" Crosslays; one [1] hose-reel; one [1] Honda EM 5000 or equivalent generator; one [1] extendable quartz scene light; one [1] ground ladder; two [2] hand-lines with/nozzles; one [1] PPV Fan; three [3] SCBA seats; and one [1] SCBA bottle storage area compartment. There will be storage compartments on both sides of the Pumper-Apparatus.

Pumper-Apparatus Water-Tank:

The Pumper-Apparatus will be equipped with a [minimum] 500 gallon polypropylene water-tank

Pumper-Apparatus Pump/Motor:

The Pumper-Apparatus will be equipped with a [minimum] 1250 GPM Waterous pump or equivalent

Pumper-Apparatus Pump Panel:

The Pumper-Apparatus pump-panel will contain all the necessary and appropriate Pump controls; Idle controls; Start/Stop switch; Choke; Oil pressure light; Pump outlet pressure gauges and additional necessary controls.

Pumper-Apparatus Foam System:

The Pumper-Apparatus will have a class A & B Foam System and will be operated with one knob/lever that will control the concentration of foam emitted. The foam system will have a means of preventing foam from going into the water tank. The Pumper-Apparatus Foam System will have one [1] 20-gallon foam cell; and one [1] 40-gallon foam cell.

Pumper-Apparatus Additional Requirements:

The Pumper-Apparatus will be furnished with: Pump-test records for past three [3] years; all Maintenance Records available; all Maintenance Manuals for Pumper-Apparatus, Pump, and Foam Systems; and available Hose-Test records for supplied hoses.